

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 15/26

Dated: 13.07.2026

It is certified that an inspection team headed by MR. Pawan Kumar Assistant Engineer

(Name of Officers with designation) from U.P. Jal Nigam Ambedkar Nagar PHED

inspected the Sangyan Global Academy Kannupur, Jalalpur, Ambedkar Nagar

(Name & Address of the school) on 10.07.2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Chemical test/10072026/26 dated 13.07.2026

of U.P. Jal Nigam (Rural) Ambedkar Nagar (PHED Lab) certified that

the Sangyan Global Academy (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 13.07.2027

Signature with Seal:

Name

Designation

Name & Address of the Office / Department:

Mr. Pawan Kumar

Assistant Engineer

Ambedkar Nagar

To Sangyan Global Academy
Kannupur, Jalalpur, Ambedkar Nagar
(Name & Address of the Institution)

Assistant Engineer
C.D.U.P. Jal Nigam
Ambedkar Nagar

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Pratiksha
Pratiksha Pandey
Sangyan Global Academy
Kannupur, Jalalpur-A.N.





TEST REPORT DISTRICT LEVEL WATER ANALYSIS LABORATORY OF UTTAR PRADESH JAL NIGAM (RURAL), AMBEDKAR NAGAR



ULR NO-TC/1721726000000150F

Report No. Chemical Test/1007202601/2026-27

Customer Details- SANGYAN GLOBAL ACADEMY KANNUPUR, JALALPUR, AMBEDKAR NAGAR

Date

13.07.2026

S.No-01

SAMPLE CODE

JL1007202601

Office Name and Address

Office of executive engineer, khand karyalay, U.P. Jal Nigam(Rural), Sabun gali, Akbarpur, District-Ambekar

Ref Letter No & Date

NA

District

AMBEDKAR NAGAR

Gram Panchayat

KANNUPUR

Habitation

SANGYAN GLOBAL ACADEMY

Water Source

BORWELL

Quantity of Sample

1 L

Receiving Date

10.07.2026

Sample Depositor

ABHISHEK VERMA

Analysis Start Date

13.07.2026

Basic details of sample

Block

JALALPUR

Village

KANNUPUR

Location

KHAS

Sample No.

1

Date of S.C.

10.07.2026

S. Collector

ABHISHEK VERMA

S. Method

IS 17614 (PART-05)-2021

Analysis Completion Date

13.07.2026

Temperature

Environmental Condition

25±3 °C

Relative Humidity

50%±15%

Technical Data of Analysis

S.No.	Analysed parameters	Unit of Measure ment	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2	3	4	5	6	7
1	Odour	NA	Agre	Agreeable	Agreeable	IS 3025(Part 05):2018
2	Taste	NA	Agre	Agreeable	Agreeable	IS 3025(Part 8):2023
3	Colour	HU	5.00	5	15	IS 3025(Part 04):2021
4	pH	NA	7.36	6.50	8.50	IS 3025(Part 11):2022
5	Turbidity	NTU	0.64	1	5	IS 3025(Part 10):2023
6	TDS	mg/L	370.00	500	2000	IS 3025(Part 16):2023
7	Alkalinity	mg/L	336.00	200	600	IS 3025(Part 23):2023
8	Chloride	mg/L	20.00	250	1000	IS 3025(Part 32):2019
9	Hardness	mg/L	272.00	200	600	IS 3025(Part 21):2023
10	Calcium	mg/L	131.27	75	200	IS 3025(Part 40):2024
11	Magnesium	mg/L	58.46	30	100	APHA 24rd Edition -3500 Mg By Calculation Method
12	Sulphate	mg/L	32.72	200	400	IS 3025(Part 24):2022
13	Nitrate	mg/L	0.20	0	45	APHA 24rd EDITION -3500 NO3-B method
14	Nitrate	mg/L	0.27	1	1.5	IS 3025(Part 60):2023
15	Fluoride	mg/L	0.14	0	1	IS 3025(Part 53):2024
15	Iron	mg/L				N/A

1. Statment of conformity

2. Reporting opinions and Interpretations ISO 17025

Note:-

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Principal

Pratiksha Pandey

Laboratory Contact details- Mob: 9981490366
Jalalpur, Ambekar Nagar



Authorized Signatory
VIKAS KUMAR
Technical Manager

Technical Manager

District Level Water Analysis Laboratory
UPJN Ambekar Nagar



TEST REPORT
DISTRICT LEVEL WATER ANALYSIS LABORATORY OF
UTTAR PRADESH JAL NIGAM (RURAL), AMBEDKAR
NAGAR

(Non NABL
Accredited
parameter)

Report No-	Chemical Test/ 1007202601/2026-27		
Customer Details-	SANGYAN GLOBAL ACADEMY KANNUPUR, JALALPUR, AMBEDKAR NAGAR		
Office Name and Address	Date	S.No.	SAMPLE CODE
	13.07.2026	01	JL1007202601
Ref Letter No & Date	Office of excutive engineer ,khand karyalay, U.P. Jal Nigam(Rural),Sabun gali,Akbarpur,District-Ambedkar Nagar ,Pin-224122		
	NA		

Basic details of sample			
District	AMBEDKAR NAGAR		
Gram Panchayat	KANNUPUR	Block	JALALPUR
Habitation	SANGYAN GLOBAL ACADEMY	Village	KANNUPUR
Water Source	BORWELL	Location	KHAS
Quantity of Sample	1 L	Sample No.	1
Receiving Date	10.07.2026	Date of S.C.	10.07.2026
Sample Depositor	ABHISHEK VERMA	S. Collector	ABHISHEK VERMA
Analysis Start Date	13.07.2026	S.Method	IS 17614 (PART-05)-2021
		Analysis Completion Date	13.07.2026

Environmental Condition			
Temperature	25± 3 °C	Relative Humidity	50%±15%

Technical Data of Analysis						
S.No.	Analysed parameters	Unit of Measure ment	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
				5	6	7
1	2	3	4	5	6	7
16	Free Residual Chlorine	mg/L	0.00	0.2	1	IS 3025(Part-26):2004
17	E.coli	H2S Vials	0.00	0	0	H2S Vials
						N/A
						N/A

- 1.Statment of conformity
2.Reporting opinions and Interpretations ISO 17025

Note:-

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Lab Technician
Prepared By

End of Test Report

Authorized Signatory
VIKAS KUMAR
Technical Manager

Technical Manager

District Level Water Analysis Laboratory
UPJN Ambedkar Nagar

Pratiksha Pandey
Principal
Sangyan Global Academy
Kannupur,Jalalpur-A.N.

